



POWER REQD: 117Vac, 8 AMP PER BANK  
3 BANKS REQD THIS SIDE, TOTAL 24 AMP

- NOTE:
1. INSTALL SIDE FRAMES WITH OPEN SIDE FACING HEPA'S, LONG LEG TOP, SHORT LEG BOTTOM
  2. INSTALL SUITABLE, PROTECTED PER CODE 120Vac 32 AMP POWER SOURCE WITH 3 RECEPTACLES ON EACH SIDE WALL BEHIND SIDE FRAME FLANGE
  3. ACCESS DOOR INTERLOCK SWITCHES REQUIRED WITH RELAY FOR 32 AMP LOAD
  4. INSTALL RACK ASSEMBLIES WITH CORDS TOWARD THE SIDE WALLS
  5. CLEAN THE EMITTER TUBES USING CLEANING KIT SA-CK03
  6. INSTALL EMITTERS, NOTE DOUBLE CLICK SOCKET
  7. TEST SYSTEM

B	3/24 97	ADD INST. DETAILS	RMC
A	1/17 97	FIRST ISSUE	RMC
REV	DATE		DFT

NEXT ASS'Y \_\_\_\_\_ WT. \_\_\_\_\_

**6 - RACK ASS'Y**  
**60 - DE241VO EMITTERS**  
**JEROME CHEESE WHEY PLANT**

		DRAWING NO.	REV.
		9701751	B